

About Drinking Water Contaminants

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The United States Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium & other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lakes Region Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing cold water from your tap for at least 30 seconds before using water for drinking or cooking. Do not use hot water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791). You may also visit the EPA website located at: <http://water.epa.gov/drink/info/lead/index.cfm>.

Are all Contaminants Harmful?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the US Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

How do I get Involved?

For more information about your drinking water, please call the owner, Thomas Mason at (603) 476-2348 or the primary operator, Justin Benes, at (603) 476-2348. Although Lakes Region does not hold public participation meetings, you are welcome to contact us with questions and concerns. For more info concerning public participation opportunities in your community, contact your Homeowner's Association President.

Source Assessment Reports: The DES prepared such reports for all public water systems from 2000-2003 in an effort to assess the vulnerability of the state's public water supply sources. The information below is 10+ years old and includes information that was current at the time the report was completed. Therefore, some of the ratings might be different if updated to reflect current information. At the present time, the DES has no plans to update this data. The complete Source Assessment Report is available for review at LRWC's office in Moultonborough, NH. For more information contact our office or visit the NHDES' website at:

<http://des.nh.gov/organization/divisions/water/dwqb/dwspp/dwsap.htm>

| Hidden Valley CWS | | Susceptibility Factor Ratings | | |
|--------------------------|---|-------------------------------|-----|------|
| Source Name | Date | Low | Med | High |
| Bedrock Well #1 (orange) | 10/17/02 | 8 | 2 | 2 |
| Bedrock Well #2 (blue) | 10/17/02 | 9 | 2 | 1 |
| Bedrock Well #2 (HVS 2) | 8/17/00 | 8 | 3 | 1 |
| Bedrock Well #5 (new) | The NHDES has not completed a SAR for this well source. | | | |

2019 Consumer Confidence Report

*For Hidden Valley
in Tuftonboro, NH
EPA ID# 2372020*



420 Governor Wentworth Hwy, PO Box 389
Moultonboro, NH 03254
Phone: 603-476-2348, Fax: 603-476-2721
www.Lakesregionwater.com
Lrwater@Lakesregionwater.com

What is a Consumer Confidence Report?

The consumer confidence Report (CCR) details the quality of your drinking water, where it comes from, and where you can get more information. This annual report documents only detected primary and secondary drinking water parameters, and compares them to their respective standards known as Maximum Contaminant Levels (MCLs). The enclosed sampling results are from the most recent monitoring done in compliance with state/federal regulations through 2018. Results prior to 2018 will include the date the sample was taken. The State of New Hampshire allows water systems to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Thus some of the data present, though representative, may be more than one year old. Lab results may be viewed on the NHDES website located at: <http://www2.des.state.nh.us/DESONestop/BasicSearch.aspx>. Enter the EPA ID listed on the front cover of this report, click Enter, and then click on the "Public Water System" link to get started.

Where Does My Water Come From?

Lakes Region Water Company (LRWC) owns & operates four active wells. Recently deepened Bedrock well #2 (HVS #2) is now approximately 1000 feet (ft.) deep, yields 12 gallons per minute (GPM) and is located 30 ft. southeast of the new lower pumphouse (PH). Bedrock Well #2 (Blue Well) is about 700 ft. deep, yields 6-7 gpm and is located 145 ft. east of the upper PH. Bedrock well #5 (new well) is approx. 800 ft. deep, yields 10 gpm and is located at the end of Aspen Drive, about 2168 ft. northeast of the upper PH. Bedrock Well #1 (Orange well) is 1300 feet deep, yields 7 gpm and is located 5 feet west of the upper PH. BRW #1 (orange) was taken offline in 2008 due to low productivity. It will be used as a mechanical backup as needed.

Violation, Treatment & Other Info

There were no violations in 2018. BRW#2 has UV Treatment to ensure microbial contaminants are not present.

Definitions:

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. (MCLGs allow for a margin of safety.)

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. They are set as close to the MCLGs as feasible using the best available treatment technology.

AL (Action Level): The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

Abbreviations:

ppm: parts per million

ppb: parts per billion (µg/L)

pCi/L: pico curies per liter

µg/L: micrograms per liter

ND: not detectable at testing limits **N/A**: Not Applicable

DETECTED WATER QUALITY RESULTS

| Contaminant (Units) | Level Detected | MCL | MCLG | Violation Yes/No | Likely Source of Contamination | Health Effects (Env-DW 811.21) |
|---------------------------------|---------------------|-----|------|------------------|--|--|
| Radioactive Contaminants | | | | | | |
| Uranium (ug/L) | 2.5 09/3/2016 | 30 | 0 | NO | Erosion of natural deposits | Some people who drink water containing uranium in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity. |
| Compliance Gross Alpha (pCi/L) | 2.7 09/13/2016 | 15 | 0 | NO | Erosion of natural deposits | Certain minerals are radioactive and may emit a form of radiation know as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer. |
| Combined Radium (pCi/L) | 0.1 09/12/2016 | 5 | 0 | NO | Erosion of natural deposits | Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer. |
| Inorganic Contaminants | | | | | | |
| Arsenic (ppb) | 0.003 10/24/2017 | 10 | 0 | NO | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes | (5 ppb through 10 ppb) While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. |

| | | | | | | |
|-----------------------------|---|--------|-----|----|---|---|
| Barium (ppm) | 0.003 10/24/2017 | 2 | 2 | NO | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits | Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure. |
| Chromium (ppb) | ND 07/14/2015 | 100 | 100 | NO | Discharge from steel and pulp mills; erosion of natural deposits | Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis. |
| Copper (ppm) | 90 th Percentile as calculated by NHDES: 0.0011 on 6/18/18 No customer sites exceeded the AL of 1.3 | AL=1.3 | 1.3 | NO | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives | Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor. |
| Fluoride (ppm) | 0.68 & 0.11 10/24/2017 | 4 | 4 | NO | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories | Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling also known as dental fluorosis, may include brown staining and/or pitting of the teeth and occurs only in developing teeth before they erupt from the gums. |
| Lead (ppb) | 90 th Percentile as calculated by NHDES: 10 on 6/18/18 No customer sites exceeded the AL of 15. | AL=15 | 0 | NO | Corrosion of household plumbing systems, erosion of natural deposits | Infants & young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and & flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791). |
| Nitrate (as Nitrogen) (ppm) | 0.5 10/24/2017 | 10 | 10 | | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits | (5 ppm through 10ppm) Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider. |
| Zinc | 0.051 & 0.028 10/24/2017 | | | NO | | We Are Required to Regularly Sample for Zinc |
| Sulfate | 4 & 8 10/24/2017 | | | NO | | We Are Required to Regularly Sample for Sulfate |
| Chloride | 5 & 36 10/24/2017 | | | NO | | We Are Required to Regularly Sample for Chloride |
| Hydrogen Ion (PH) | 7.3 & 7 10/24/2017 | | | NO | | We Are Required to Regularly Sample for Hydrogen Ion (PH) |