

## About Drinking Water Contaminants

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The United States Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* & other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

## Lead Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lakes Region Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing cold water from your tap for at least 30 seconds before using water for drinking or cooking. Do not use hot water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791). You may also visit the EPA website located at <http://water.epa.gov/drink/lead/index.cfm>.

## Are all Contaminants Harmful?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the US Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

## How do I get Involved?


For more information about your drinking water, please call the owner, Thomas Mason at (603) 476-2348 or the primary operator, Justin Benes, at (603) 476-2348. Although Lakes Region does not hold public participation meetings, you are welcome to contact us with questions and concerns. For more info concerning public participation opportunities in your community, contact your Homeowner's Association President for dates & times of Association meetings.

## Violations, Treatment & Other Info

We are pleased to report that there were NO violations issued for the Lake Ossipee Village Community Water System during the year 2016! In May 2010, Lakes Region Water installed a new corrosion control treatment method that was approved by the NHDES as a way to keep lead and copper at reduced levels within the distribution system. Utilizing a Georgia Marble Calcite Contacter, a naturally occurring compound, this has proven to be highly effective in keeping lead and copper at safe and acceptable levels. This is evidenced by the reduced levels that have been maintained since 2010 to present.

# 2017 Consumer Confidence Report

For Lake Ossipee Village in  
Freedom, NH  
EPA ID# 0862010



420 Governor Wentworth Hwy, PO Box 389  
Moultonboro, NH 03254  
Phone: 603-476-2348, Fax: 603-476-2721  
[www.lakesregionwater.com](http://www.lakesregionwater.com)  
[Lrwater@Lakesregionwater.com](mailto:Lrwater@Lakesregionwater.com)

**What is a Consumer Confidence Report?**

The consumer confidence Report (CCR) details the quality of your drinking water, where it comes from, and where you can get more information. This annual report documents only detected primary and secondary drinking water parameters, and compares them to their respective standards known as Maximum Contaminant Levels (MCLs). The enclosed sampling results are from the most recent monitoring done in compliance with state/federal regulations through 2016. Results prior to 2016 will include the date the sample was taken. The State of New Hampshire allows water systems to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Thus some of the data present, though representative, may be more than one year old. Lab results may be viewed on the NHDES website located at: <http://www2.des.state.nh.us/DESonestop/BasicSearch.aspx>. Enter the EPA ID listed on the front cover of this report, click Enter, and then click on the "Public Water System" link to get started.

**Where Does My Water Come From?**

Lakes Region Water Company (LRWC) owns & operates 3 active gravel packed wells. Gravel packed well #1 is approximately 50 feet deep, yields 45 gallons per minute (GPM) and is located 175 ft. west-SW of the pump house. Gravel packed well #2 yields 35 GPM, is about 45 ft. deep & is located 80 ft. WSW of the pump house. Gravel packed well #3 is approx. 50 ft. deep, is located 52 ft. south of the pump house & produces 35 GPM.

| Source Assessment Information (prepared by the NHDES) |         |     |        |      |
|---|---------|-----|--------|------|
| Source Name   | Date    | Low | Medium | High |
| Lake Ossipee Village                                  |         |     |        |      |
| Gravel Pack Well #1                                   | 1/11/00 | 9   | 2      | 1    |
| Gravel Pack Well #2                                   | 1/11/00 | 9   | 2      | 1    |
| Gravel Pack Well #3                                   | 1/11/00 | 9   | 2      | 1    |

DES prepared drinking water source assessment reports for all public water systems between 2000 and 2005 in an effort to assess the vulnerability of each of the state's public water supply sources. The information above is over 10 years old and includes information that was current at the time the report was completed. Therefore, some of the ratings might be different if updated to reflect current information. At the present time, the DES has no plans to update this data. The complete Source Assessment Report is available for review at LRWC's office in Moultonborough, NH. For more information call Justin at 603-476-2246 or visit the NHDES' <http://des.nh.gov/granzation/divisions/water/owh/bwswsp/dwswsp.htm>

**Definitions:**

**MCLG** (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. (MCLGs allow for a margin of safety.)

**MCL** (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. They are set as close to the MCLGs as feasible using the best available treatment technology.

**AL** (Action Level): The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

**DETECTED WATER QUALITY RESULTS**

| Contaminant (Units)               | Level Detected  | MCL    | MCLG | Violation Yes/No | Likely Source of Contamination  | Health Effects (Env-DW 814.21)  |
|-----------------------------------|---|--------|------|------------------|---|---|
| <b>Inorganic Contaminants</b>     |   |        |      |                  |   |   |
| Barium (ppm)                      | 0.01<br>9/02/2014   | 2      | 2    | NO               | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                                | Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.  |
| Copper (ppm)                      | 90 <sup>th</sup> Percentile as calculated by NHDES on 9/13/2016 is 0.5<br>No sites exceeded the AL of 1.3 | AL=1.3 | 1.3  | NO               | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                    | Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.   |
| Fluoride (ppm)                    | 0.2<br>09/02/2014   | 4      | 4    | NO               | Erosion of natural deposits; water additive which promotes strong leach; discharge from fertilizer and aluminum factories | Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.   |
| Nitrate (as Nitrogen) (ppm)       | 0.8<br>9/13/2016  | 10     | 10   | NO               | Runoff from fertilizer use; leaching from septic tanks; seepage; erosion of natural deposits                              | (5 ppm through 10ppm) Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.  |
| Lead (ppb)                        | 90 <sup>th</sup> Percentile as calculated by NHDES on 9/13/2016 is 5.0<br>No sites exceeded the AL of 15. | AL=15  | 0    | NO               | See lead info on back cover<br>Corrosion of household plumbing systems; erosion of natural deposits                       | Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap water for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791). |
| <b>Radioactive Contaminants</b>   |   |        |      |                  |   |   |
| Compliance Gross Alpha (pCi/L)    | 2.1<br>9/13/2016  | 15     | 0    | NO               | Erosion of natural deposits   | Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.  |
| Combined Radium 226 + 228 (pCi/L) | 0.9<br>9/13/2016  | 5      | 0    | NO               | Erosion of natural deposits   | Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.   |
| Uranium (ug/l)                    | 2.3<br>9/13/2016  | 30     | 0    | NO               | Erosion of natural deposits   | Some people who drink water containing uranium in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity.   |

**Abbreviations:**

**ppm:** parts per million  
**ppCi/L:** pico curies per liter  
**ND:** not detectable at testing limits

**ppb:** parts per billion (ug/L)  
**ug/L:** micrograms per liter  
**N/A:** Not Applicable